

**PWS ID:** LA1039018

**Water System Name:** Pine Prairie Correctional Facility WS

**Type Code:** Community Water System

**Activity Status:** Active

**Primary Source:** Ground Water (2 active wells)

**Treatment:** Hypo-Chlorination.

Flow: Well 1 to Treatment Plant TP001

Well 2 to Treatment Plant TP001

TP001 to Ground Storage Tank GR001

GR001 to Hydroneumatic Tank HD001

Violations in Fed Data Warehouse (federal data base of record), data frozen as of 10/1/2015:

Violation ID	Violation type	Analyte	Violation Begin Date	Violation End Date
8	Monitoring and Reporting (DBP)	Total Trihalomethane (TTHM)	11/1/2013	10/31/2014
9	Monitoring and Reporting (DBP)	Total Haloacetic Acids (HAA5)	11/1/2013	10/31/2014
6	Monitoring and Reporting (DBP)	Total Trihalomethane (TTHM)	1/1/2013	10/31/2013
7	Monitoring and Reporting (DBP)	Total Haloacetic Acids (HAA5)	1/1/2013	10/31/2013
3	Monitoring, Regular	Residual Chlorine	9/1/2012	9/30/2012